



ST. ANTONY FIRE SERVICES

FOR A SAFER TOMORROW

REGD. OFFICE- 1/204, OPP. ST. JOSEPH CONVENT, NORTH CHERANELLOOR, COCHIN - 682034
MOBILE - +919495851561, SAFIRECARE@GMAIL.COM

SA/FC/006/06/2017

CERTIFICATE

This is to certify that we inspected the Building of **M/S. AL MANAR SENIOR SECONDARY SCHOOL**, Erattupetta P O, Kottayam dist., Meenachil Taluk, Erattupetta Municipality ward no. VI, Building no- 372 on 08-06-2017 and found the fire and safety arrangements are in good condition.

All the doors and stairs are easily recognizable and unobstructed.

All the electrical outlets, switches and junction boxes are properly covered also the electrical system is safe from shock or other electrical hazards.

As per the inspection the below mentioned Fire Extinguishers are installed or refilled on 08/06/2017 and kept ready to use till 08/06/2018.

Sl. No	Type of fire Extinguisher	Capacity	Class of Fire	No's
1	ABC	4 KG	A/B/C	5
2	ABC	5 KG	A/B/C	10

Place: ERATTUPETTA

Date: 08/06/2017



T.T. Antony
8/06/2017
T. T ANTONY
Chief Consultant
Station Officer (Retd.)
Kerala Fire & Rescue Service